



# THE CITADEL

<b>Solicitation Number</b>	<b>IFB 25014-JF</b>
<b>Addendum #</b>	<b>1</b>
<b>Date Issued</b>	<b>02/07/2025</b>
<b>Procurement Officer</b>	<b>Jessica Favor, NIGP-CPP, CPPB, CPPO</b>
<b>Phone</b>	<b>843-953-2737</b>
<b>E-Mail Address</b>	<b>jfavor@citadel.edu</b> <b>procurement@citadel.edu</b>

## SOLICITATION TITLE: IFB 25014-JF – Elevator Modernization for Byrd Hall

### TYPE OF ADDENDUM:

- Change or clarification to the Solicitation’s specifications, requirements, or scope of work.
- Questions posed regarding the Solicitation and their respective answers by The Citadel.

### Questions:

1. Will the fire panel/smoke head/addressable relays be handled by the Citadel directly or will this need to be included in the base price with the bid?  
All alarm and smoke heads concerns will be addressed by the citadel prior to project start.
2. Will the Citadel be providing an internet connection for the two-way communication or do we need to provide a cellular option for the two-way communication in the bid?  
Please note – a cellular option will create a monthly charge for monitoring after installation.  
The citadel will be providing network connectivity for communications.
3. Is there a preferred day of the week/street location designated for any necessary crane work?  
Contractor will be able to utilize either Richardson or Jones Ave. for crane operation with proper scheduled notification to all parties involved in traffic control.
4. What is the estimated budget? Bid pending.

Other Change: Describe

### IMPORTANT NOTICE:

X Contractor is required to acknowledge receipt of this Addendum by signing below and returning a copy with its Offer.

Except as provided herein, all terms and conditions of the Solicitation referenced above remain unchanged and in full force and effect.

### SIGNATURE OF PERSON AUTHORIZED TO EXECUTE ON BEHALF OF OFFEROR

Signature: \_\_\_\_\_

Printed Name & Title: \_\_\_\_\_

Company Name: \_\_\_\_\_

Date: \_\_\_\_\_